



THE ADMINISTRATION OF UNION TERRITORY OF LADAKH
OFFICE OF THE DIRECTOR FIRE AND RESCUE SERVICES UT LADAKH

(Office Phone Number.01982-260888)

Number: - F&RS/Dir/NOC/2025-644-45

Dated: - 30/06/2025

Subject: Fire NOC of Govt High School Minjee, Kargil.

The report has been submitted by Deputy Director, F&RS Ladakh regarding the inspection of the instant School building wherein the spot visit has been conducted by DFO Fire and Rescue Services Station, Kargil. The detailed report of the school building is as under:

Location / Accessibility:

The school building is constructed at Minjee, Kargil. It is located at latitude 34.488502 and longitude 76.100460. The site is approximately 10 Kms away from Fire and Rescue Service Station Kargil. It takes approximately 15 minutes to reach the site which is approachable for fire appliances.

Detail of building:

The school has plot area about 605.25007 sq. mtrs while as plinth area is about 315.774 sq. mtrs. As per code 3.1.2 of the NBC 2016 the building falls under Group "B" Educational buildings. Subdivision B-2 All other/ training institutions. There are around 136 students and 19 staff members in the school. The height of the school is 06 meters. The school building has three blocks. The details of the block are as under:

1st Block: It is single stored building having 02 number of examination halls, two store rooms and a mid-day meal kitchen. There are two windows in each room and the size is 6x4 feet. Two sides of the windows have provision to open.

2nd block: It is three storied having two staircases. On the ground floor there are ICT lab and examination section. There is one window in each and the size is 6x4xfeet. two class rooms and one window in each class room. Two sides of the windows have provision to open. The 1st floor has laboratory room and 2nd floor has library.

3rd block: It is two storied building having two stair case. On the ground floor there are headmaster office, staff room, sport room, library room, laboratory room and 04 number of store room. There are two windows in each room and the size is 6x4 feet. Two sides of Windows have provision to open. 1st floor has staff room, smart class room, assembly hall and 05 number of class room. Accordingly, the following Minimum firefighting installation are required and applied.

The following Fire Safety equipment's which are installed in School Building:

1. 03 number of fire extinguishers ABC Type 06 kg capacity and 06 number of fire extinguishers 02 kg capacity are installed in the school building.
2. 04 number of sand bucket is installed in the school building.
3. 02 number of plastic water tank 1000 liters capacity overhead of the building.
4. 05 thousand liters underground reserve water tank is installed in the school premises.

As per the field report, the above equipment were found to be in place. **FIRE NOC** is given in the favour **Govt High School Minjee, Kargil** for period of **One year** from the issuance.


Director,
Fire and Rescue Services,
UT Ladakh,
FIRE & RESCUE SERVICE
UT-LADAKH

Copy to:

1. Headmaster, Prop. Govt High School, Kargil for information.
2. Deputy Director, F&RS, Ladakh for information.
3. Office file.